

SOLDIER CANYON WATER TREATMENT AUTHORITY

(East Larimer County Water District; Fort Collins/Loveland Water District; North Weld County Water District)

WATER QUALITY REPORT

2ND QUARTER 2025

ANALYSIS PARAMETER <small>Monitored at SCFP (not a certified lab)</small>	Report	PLANT INFLUENT			PLANT EFFLUENT			MCL *SMCL
	Values	MIN	MAX	AVG	MIN	MAX	AVG	
ALKALINITY	mg/l	13.0	30.0	23.4	34.0	38.0	36.0	N/A
ALUMINUM	mg/l	N/A	N/A	N/A	0.018	0.054	0.038	*0.05 - 0.2
CALCIUM HARDNESS	mg/l	12.0	24.0	19.6	17.0	22.0	19.7	N/A
CHLORINE	mg/l	N/A	N/A	N/A	1.24	1.44	1.34	4.0 MRDL
CHLORITE	mg/l	N/A	N/A	N/A	0.33	0.75	0.51	1.0
CHLORINE DIOXIDE	mg/l	N/A	N/A	N/A	0.00	0.07	0.00	0.8
CONDUCTIVITY	µs/cm	36.9	78.8	62.9	99.4	112.0	105.2	N/A
DISSOLVED OXYGEN	mg/l	7.8	11.7	9.1	N/A	N/A	N/A	N/A
FLUORIDE	mg/l	0.05	0.32	0.17	0.12	0.74	0.62	4.0/*2.0
HARDNESS (TOTAL)	mg/l	14.0	32.0	21.9	21.0	32.0	24.6	N/A
IRON	mg/l	0.00	0.13	0.06	0.01	0.01	0.01	*0.3
MANGANESE	mg/l	0.010	0.023	0.016	0.002	0.006	0.004	*0.05
pH	VALUE	6.83	8.17	7.42	8.15	8.54	8.33	*6.5-8.5
TEMPERATURE	°C	3.3	16.1	9.0	4.6	12.9	9.1	N/A
TRUE COLOR	APHA	5.0	48.0	22.5	0.0	1.0	0.7	*15.0
TURBIDITY	NTU	0.65	12.34	1.89	0.013	0.043	0.015	**<0.3 TT

INORGANIC CONTAMINANTS ANALYSES (CA) - (EFFLUENT ENTRY POINT AT SCFP)

		RESULTS	DATE	MCL
ANTIMONY	mg/l	BDL	8/7/2024	0.006
ARSENIC	mg/l	BDL	8/7/2024	0.010
BARIUM	mg/l	0.014	8/7/2024	2.000
BERYLLIUM	mg/l	BDL	8/7/2024	0.004
CADMIUM	mg/l	BDL	8/7/2024	0.005
CHROMIUM	mg/l	BDL	8/7/2024	0.1
FLUORIDE	mg/l	0.70	8/7/2024	4.0
MERCURY	mg/l	BDL	8/7/2024	0.002
NICKEL	mg/l	BDL	8/7/2024	N/A
SELENIUM	mg/l	BDL	8/7/2024	0.050
SODIUM	mg/l	11.1	8/7/2024	N/A
THALLIUM	mg/l	BDL	8/7/2024	0.002

NITRATE AND/OR NITRITE AS NITROGEN (CA) - (EFFLUENT ENTRY POINT AT SCFP)

		RESULTS	DATE	MCL
NITRATE	mg/l	2.000	7/15/2024	10.000
NITRITE	mg/l	BDL	7/15/2024	1.000
NITRATE	mg/l	BDL	8/7/2024	10.000
NITRATE	mg/l	0.200	10/9/2024	10.000

TOTAL ORGANIC CARBON (SCWQL) - (SCFP INFLUENT AND EFFLUENT)

			INFLUENT	EFFLUENT	TT RATIO	DATE	MCL - **TT
TOTAL ORGANIC CARBON - TOC	mg/L		3.84	2.13	1.27	4/16/2025	RAA - ≥1.0
			4.58	2.13	1.19	4/16/2025	RAA - ≥1.0
			4.96	2.22	1.23	5/7/2025	RAA - ≥1.0
			6.45	2.22	1.46	5/7/2025	RAA - ≥1.0
			3.70	1.78	1.48	6/11/2025	RAA - ≥1.0
			3.74	1.78	1.50	6/11/2025	RAA - ≥1.0

			INFLUENT	DATE	MCL
ALKALINITY (SCWQL) - (SCFP INFLUENT)	mg/l		26.0	4/16/2025	N/A
			26.0	4/16/2025	N/A
			23.0	5/7/2025	N/A
			20.0	5/7/2025	N/A
			25.0	6/11/2025	N/A
			22.0	6/11/2025	N/A

RADIONUCLIDE ANALYSES (SGS) - (EFFLUENT ENTRY POINT AT SCFP)

			RESULTS	DATE	MCL
GROSS ALPHA	pCi/L		ND	9/8/2021	15
URANIUM	ppb		<0.00020	9/8/2021	30
RADIUM 226 + 228	pCi/L		ND	9/8/2021	5
GROSS BETA	pCi/L		ND	9/8/2021	50

ORGANIC CHEMICAL ANALYSES - VOC's (CA) - (EFFLUENT ENTRY POINT AT SCFP)

			RESULTS	DATE	MCL
1,1,1-TRICHLOROETHANE	µg/L		BDL	7/15/2024	200
1,1,2-TRICHLOROETHANE	µg/L		BDL	7/15/2024	5
1,1-DICHLOROETHYLENE	µg/L		BDL	7/15/2024	7
1,2,4-TRICHLOROBENZENE	µg/L		BDL	7/15/2024	70
1,2-DICHLOROETHANE	µg/L		BDL	7/15/2024	5
1,2-DICHLOROPROPANE	µg/L		BDL	7/15/2024	5
BENZENE	µg/L		BDL	7/15/2024	5
CARBON TETRACHLORIDE	µg/L		BDL	7/15/2024	5
CHLOROBENZENE	µg/L		BDL	7/15/2024	100
cis-1,2-DICHLOROETHYLENE	µg/L		BDL	7/15/2024	70
DICHLOROMETHANE	µg/L		BDL	7/15/2024	5
ETHYLBENZENE	µg/L		BDL	7/15/2024	700
o-DICHLOROBENZENE	µg/L		BDL	7/15/2024	600
para-DICHLOROBENZENE	µg/L		BDL	7/15/2024	75
STYRENE	µg/L		BDL	7/15/2024	100
TETRACHLOROETHYLENE	µg/L		BDL	7/15/2024	5
TOLUENE	µg/L		BDL	7/15/2024	1000
trans-1,2-DICHLOROETHYLENE	µg/L		BDL	7/15/2024	100
TRICHLOROETHYLENE	µg/L		BDL	7/15/2024	5
VINYL CHLORIDE	µg/L		BDL	7/15/2024	2
XYLENES (total)	µg/L		BDL	7/15/2024	10000

ORGANIC CHEMICAL ANALYSES - SOC's (CA) - (EFFLUENT ENTRY POINT AT SCFP)			RESULTS	DATE	MCL
1,2-DIBROMO-3-CHLOROPROPANE	µg/L		BDL	8/7/2024	0.2
2,4-D	µg/L		BDL	8/7/2024	70
2,4,5-TP	µg/L		BDL	8/7/2024	50
ALACHLOR (LASSO)	µg/L		BDL	8/7/2024	2
ALDICARB	µg/L		BDL	8/7/2024	N/A
ALDICARB SULFONE	µg/L		BDL	8/7/2024	N/A
ALDICARB SULFOXIDE	µg/L		BDL	8/7/2024	N/A
ATRAZINE	µg/L		BDL	8/7/2024	3
BENZO(a)PYRENE	µg/L		BDL	8/7/2024	0.2
BHC-GAMMA/LINDANE	µg/L		BDL	8/7/2024	0.2
CARBOFURAN	µg/L		BDL	8/7/2024	40
CHLORDANE	µg/L		BDL	8/7/2024	2
DALAPON	µg/L		BDL	8/7/2024	200
DINOSEB	µg/L		BDL	8/7/2024	7
DIQUAT	µg/L		BDL	8/7/2024	20
DI(2-ethylhexyl)ADIPATE	µg/L		BDL	8/7/2024	400
DI(2-ethylhexyl)PHTHALATE	µg/L		BDL	8/7/2024	6
ENDOTHALL	µg/L		BDL	8/7/2024	100
ENDRIN	µg/L		BDL	8/7/2024	2
ETHYLENE DIBROMIDE	µg/L		BDL	8/7/2024	0.05
HEPTACHLOR	µg/L		BDL	8/7/2024	0.4
HEPTACHLOR EPOXIDE	µg/L		BDL	8/7/2024	0.2
HEXACHLOROBENZENE	µg/L		BDL	8/7/2024	1
HEXACHLOROCYCLOPENTADIENE	µg/L		BDL	8/7/2024	50
METHOXYCHLOR	µg/L		BDL	8/7/2024	40
OXAMYL	µg/L		BDL	8/7/2024	200
PENTACHLOROPHENOL	µg/L		BDL	8/7/2024	1
PICLORAM	µg/L		BDL	8/7/2024	500
POLYCHLORINATED BIPHENYLS	µg/L		BDL	8/7/2024	0.5
SIMAZINE	µg/L		BDL	8/7/2024	4
TOXAPHENE	µg/L		BDL	8/7/2024	3

POLYFLUOROALKYL SUBSTANCES (PFAS)(CA)			EPA PROPOSED MCL/HI			
			RESULTS	HI CALC.	DATE	MCL/HI
PFOA - Perfluorooctanoic	ng/L		ND	NA	4/23/2025	4.0 ng/L
PFOS - Perfluorooctanesulfonic acid	ng/L		ND	NA	4/23/2025	4.0 ng/L
PFNA - Perfluorononanoic acid	ng/L		ND	0	4/23/2025	10 ng/L-HI
PFHxS - Perfluorohexanesulfonic acid	ng/L		ND	0	4/23/2025	10 ng/L-HI
PFBS - Perfluorobutanesulfonic acid	ng/L		ND	0	4/23/2025	HI
HFPO-DA (GenX)	ng/L		ND	0	4/23/2025	10 ng/L-HI
HAZARD INDEX TOTAL	ng/L			0	4/23/2025	1.0 HI MCL

For more information on PFAS, please visit the EPA website at:
<https://www.epa.gov/sdwa/and-polyfluoroalkyl-substances-pfas>

DISTRIBUTION SYSTEMS SAMPLES

CHLORINE (Districts Measure)

		TOTAL SAMPLES	MIN	MAX	AVG	DATE	MRDL
EAST LARIMER COUNTY WATER DISTRICT	mg/L	30	0.31	1.13	0.88	Apr-25	4.0
EAST LARIMER COUNTY WATER DISTRICT	mg/L	30	0.40	1.08	0.85	May-25	4.0
EAST LARIMER COUNTY WATER DISTRICT	mg/L	30	0.30	1.03	0.66	Jun-25	4.0
<hr/>							
FORTCOLLINS/LOVELAND WATER DISTRICT	mg/L	70	0.55	1.22	0.84	Apr-25	4.0
FORTCOLLINS/LOVELAND WATER DISTRICT	mg/L	70	0.46	1.35	0.88	May-25	4.0
FORTCOLLINS/LOVELAND WATER DISTRICT	mg/L	70	0.44	1.29	0.84	Jun-25	4.0
<hr/>							
NORTH WELD COUNTY WATER DISTRICT	mg/L	18	0.37	1.06	0.80	Apr-25	4.0
NORTH WELD COUNTY WATER DISTRICT	mg/L	18	0.35	0.97	0.71	May-25	4.0
NORTH WELD COUNTY WATER DISTRICT	mg/L	18	0.22	0.95	0.64	Jun-25	4.0

TOTAL COLIFORMS (EN/MMS/WCL)

		TOTAL SAMPLES	# POSITIVE	# NEGATIVE	DATE	MCL **TT LEVEL 1 or 2
EAST LARIMER COUNTY WATER DISTRICT		30	0	30	Apr-25	NO/NO
EAST LARIMER COUNTY WATER DISTRICT		30	0	30	May-25	NO/NO
EAST LARIMER COUNTY WATER DISTRICT		30	0	30	Jun-25	NO/NO
<hr/>						
FT COLLINS/LOVELAND WATER DISTRICT		70	0	70	Apr-25	NO/NO
FT COLLINS/LOVELAND WATER DISTRICT		70	0	70	May-25	NO/NO
FT COLLINS/LOVELAND WATER DISTRICT		70	0	70	Jun-25	NO/NO
<hr/>						
NORTH WELD COUNTY WATER DISTRICT		18	0	18	Apr-25	NO/NO
NORTH WELD COUNTY WATER DISTRICT		18	0	18	May-25	NO/NO
NORTH WELD COUNTY WATER DISTRICT		18	0	18	Jun-25	NO/NO

DISTRIBUTION SYSTEMS SAMPLES - CONTINUED

<u>TOTAL TRIHALOMETHANES AND HALOACETIC ACIDS</u>		TTHM RESULTS	MCL (LRAA)	HAA5 RESULTS	MCL (LRAA)	DATE
<u>EAST LARIMER COUNTY WATER DISTRICT (EN)</u>						
SAMPLE SITE - DBP001	µg/L	41.3	80	34.2	60	4/8/2025
SAMPLE SITE - DBP002	µg/L	65.2	80	29.2	60	4/8/2025
SAMPLE SITE - DBP003	µg/L	18.6	80	23.4	60	4/8/2025
SAMPLE SITE - DBP004	µg/L	64.8	80	29.7	60	4/8/2025

<u>FORT COLLINS/LOVELAND WATER DISTRICT (CA)</u>						
SAMPLE SITE - DBP001	µg/L	34.90	80	33.49	60	4/2/2025
SAMPLE SITE - DBP002	µg/L	42.70	80	38.37	60	4/2/2025
SAMPLE SITE - DBP003	µg/L	36.05	80	28.99	60	4/2/2025
SAMPLE SITE - DBP004	µg/L	31.95	80	29.26	60	4/2/2025
SAMPLE SITE - DBP005	µg/L	34.56	80	26.47	60	4/2/2025
SAMPLE SITE - DBP006	µg/L	31.90	80	24.59	60	4/2/2025
SAMPLE SITE - DBP007	µg/L	39.61	80	29.17	60	4/2/2025
SAMPLE SITE - DBP008	µg/L	38.98	80	29.67	60	4/2/2025

<u>NORTH WELD COUNTY WATER DISTRICT (CA)</u>						
SAMPLE SITE - DBP001	µg/L	49.04	80	26.35	60	4/14/2025
SAMPLE SITE - DBP002	µg/L	36.61	80	35.66	60	4/14/2025
SAMPLE SITE - DBP003	µg/L	40.71	80	33.44	60	4/14/2025
SAMPLE SITE - DBP004	µg/L	36.13	80	31.40	60	4/14/2025

<u>CHLORITE (CA)</u>		1ST RES	AVG RES	MAX RES	DATE	MCL
FROM DISTRIBUTION SYSTEM(S)	mg/L	0.32	0.32	0.28	4/2/2025	1.0

<u>LEAD AND COPPER</u>		90TH PERCENTILE mg/L	DATE	90th% ACTION LEVEL mg/L
<u>EAST LARIMER COUNTY WATER DISTRICT (SGS)</u>		30 SAMPLES COLLECTED		
LEAD	mg/L	0.004	Jun-Jul-2022	0.015
COPPER	mg/L	0.19	Jun-Jul-2022	1.3

<u>FORT COLLINS LOVELAND WATER DISTRICT (CA)</u>		30 SAMPLES COLLECTED		
LEAD	mg/L	0.001	Jun-24	0.015
COPPER	mg/L	0.184	Jun-24	1.3

<u>NORTH WELD COUNTY WATER DISTRICT (WCL)</u>		30 SAMPLES COLLECTED		
LEAD	mg/L	0.00353	Aug-Sep 2024	0.015
COPPER	mg/L	0.25	Aug-Sep 2024	1.3

MCL = Maximum Contaminate Level - Enforcable

PFAS = Per- and Polyfluorinated Alkyl Substances

mg/L (ppm) = Milligrams Per Liter (Parts Per Million)

ng/L (ppt) = Nanograms Per Liter (Parts Per Trillion)

APHA = American Public Health Association color scale

***SMCL = Secondary Maximum Contaminate Level - Recommended**

****TT = Treatment Technique**

SOC = Synthetic Organic Chemicals

RAA = Running Annual Average

ACTION LEVEL = Addition treatment required if exceeded

< = Less Than

(FCL) = Fort Collins Lab (UL) = United Lab (SGS) = SGS Lab (MMS) = MMS Environmental (WCL) = Weld County Lab

(CA) = Colorado Analytical Lab (EA) = Eurofins Eaton Analytical (EN) = Eanalytics

(SCWQL) = Soldier Canyon Water Quality Lab (SCFP) = Soldier Canyon Filter Plant

BDL = Below Detectable Limit

HI - Hazard Index

µg/L (ppb) = Micrograms Per Liter (Parts Per Billion)

pCi/L = Picocuries Per Liter

µs/L = MicroSiemens Per Centimeter

ND = Not Detected NT = Not Tested

N/A = Not applicable

VOC = Volatile Organic Chemicals

LRAA = Location Running Annual Average

MRDL = Maximum Residual Disinfectant Level

> = Greater Than